

PRO-ADVANCE TECHNOLOGY CO., LTD.

9F., No.83, Sec. 3, Dusing Rd., Banciao City, Taipei County 220, Taiwan (R.O.C)

REPORT NO. : RI/2004/60016

PAGE NO. : 1 之 1

DATE : 2004/6/28

THE FOLLOWING MERCHANDISE WAS(WERE) SUBMITTED AND IDENTIFIED BY THE CLIENT AS :

PRODUCT NAME	PHYSICAL WATER CONDITIONER
SAMPLE SUBMITTED	PRO-ADVANCE TECHNOLOGY CO., LTD.
PRODUCT DESCRIPTION	1.KILL BACTERIUM 2. PREVENT SCALE
STYLE/ITEM NO.	HYDROFLOW, AQUAKLEAR, SPARKLEAR, STEAMKLEAR
MANUFACTURER	HYDROPATH (UK)LTD
COUNTRY OF ORIGIN	UK
SAMPLE RECEIVED	2004/6/11
TESTING DATE	2004/6/11

TEST ITEM / METHOD

Reference To AATCC 100 : 1. *Staphylococcus aureus* AACC 6538
 2. *Escherichia coli* AACC 8739

TEST RESULT:

TREATMENT (REACTION TIME : 1 HR)

TEST BACTERIA	Counts (Before Circulation) (CFU/ml)	Counts (After Circulation for 1 hour) (CFU/ml)	Reduction(%)
<i>Staphylococcus aureus</i>	1.2x10 ⁵	<1	99.99
<i>Escherichia coli</i>	1.3x10 ⁵	<1	99.99

THE REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL, WITHOUT THE WRITTEN APPROVAL OF THE LABORATORY.



Jeremy Li, M.R./Supervisor, Food Dept.
 Signed for and on behalf of
 SGS TAIWAN Ltd.

TW 0802232